

Kay G. Love
City Administrator

Jere Wood
Mayor

ADDENDUM 2

City of Roswell Purchasing Division

Request for Proposal #16-112-L

APRIL 19, 2016

To All Prospective Offerors:

The Due Date has been updated to be 2:00 p.m. on Monday, May 2, 2016.

In reference to the RFP listed above, the following answers to questions, additions, deletions and changes are hereby incorporated into the Request for Proposal:

Change: Section 2.2 Rooftop Airconditioning Units Section H. Heat Exchangers; stainless steel, factory tested for leaks and stress relieved.

To: Section 2.2 Rooftop Airconditioning Units Section H Heat Exchangers; aluminum, factory tested for leaks and stress relieved.

The American Standard attachment has various model numbers for which the Gas Heating Section references the heat exchangers; these should all be aluminized not stainless steel.

COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the RFP to:

**City of Roswell – Purchasing Division
Roswell City Hall
38 Hill Street, Suite 130
Roswell, GA 30075**

I hereby acknowledge receipt of Addendum 2 and have incorporated the changes into my proposal response for the above mentioned RFP.

COMPANY NAME: _____ **CONTACT PERSON:** _____

ADDRESS: _____ **CITY:** _____ **STATE:** ____ **ZIP:** ____

PHONE: _____ **FAX:** _____ **EMAIL ADDRESS:** _____

SIGNATURE: _____ **DATE:** _____