

Kay G. Love
City Administrator

Jere Wood
Mayor

ADDENDUM 1

City of Roswell Purchasing Division

INVITATION TO BID #17-129-E

May 2, 2017

To All Prospective Offerors:

The Due Date remains as 2:00 p.m. on Tuesday, May 9, 2017.

In reference to the ITB listed above, the following answers to questions, additions, deletions and changes are hereby incorporated into the Request for Proposal:

1. Are there any drawings available for the fire simulator?

Answer: Yes, there are floor plans available at www.roswellgov.com click on procurement opportunities, then click on Fire Simulator Renovations.

2. Is there any building required through this proposal?

Answer: No strictly retrofitting.

3. Do the props need to be made of stainless steel?

Answer: No, the props shall be made of carbon steel.

4. How will the fires start in the fire simulator?

Answer: They will be operator controlled by a remote.

5. How many gas monitors are required per room and how will the readings be recorded?

Answer: To follow NFPA standards two gas monitors are required by room, the readings will need to be infrared.

6. What is the purpose of the leak function for the exterior prop?

Answer: To assist in the training for additional hazmat scenarios.

7. Has the framing behind the paneling been inspected?

Answer: No, but COR personnel will complete the inspection.

8. Will there be a need to have conduit/wiring replaced?

Answer: The City will not have changes made to the existing wiring or conduit until we know the awarded vendor's specifications and needs. At that time we will have Meer Electric handle the modifications.

9. How will the exterior prop receive gas?

Answer: Gas piping is on the outside of the building a cut-off valve will be connected to the awarded vendors coupling

10. Is each fire tray a water bath?

Answer: Yes.

11. Are the readings for the gas sensors independent of each other?

Answer: No, all gas readings shall be integrated into the control cabinet/technical room.

COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the ITB to:

**City of Roswell – Purchasing Division
Roswell City Hall
38 Hill Street, Suite 130
Roswell, GA 30075**

I hereby acknowledge receipt of Addendum 1 and have incorporated the changes into my proposal response for the above mentioned ITB.

COMPANY NAME: _____ **CONTACT PERSON:** _____

ADDRESS: _____ **CITY:** _____ **STATE:** ____ **ZIP:** ____

PHONE: _____ **FAX:** _____ **EMAIL ADDRESS:** _____

SIGNATURE: _____ **DATE:** _____