

**City of Roswell
Purchasing Division**

**Gary Palmer
City Administrator**

**Lori Henry
Mayor**

ADDENDUM NUMBER 2

INVITATION TO BID # 18-297-G

**NORCROSS STREET CULVERT REPLACEMENT
November 21, 2018**

To All Prospective Offerors:

In reference to the ITB listed above, the following Changes and Answers to Questions are hereby incorporated into the Invitation to Bid:

Questions and Answers:

| QA# | Question | Answer |
|-----|--|---|
| 1 | Will the City be putting in a contingency? | Any contingency will not be a contractor's contingency, and will not affect the bid price. |
| 2 | We understand the liquidated damages portion of the Bid, but want to make sure that finish work can be done under traffic. Can finish work be done under traffic? | Finish work can be done under traffic. |
| 3 | When is work anticipated to begin? Can you walk me through the specific streets that cannot be used on the detour plan? Is there any reason why RDOT does not want to put together the plan? | Work is anticipated to begin in January. The awarded contractor will submit a traffic plan for review and approval by RDOT. We do not know the specific streets that cannot be used on the detour plan. |

| QA# | Question | Answer |
|-----|---|--|
| 4 | There are some concerns with the immediately adjacent water main / valve. The concern is that it is so close to the ditch that it may lose support during the course of construction. Is there a plan to address the issue and if not what can we do? A line has been included in the bid tab for shoring. It is anticipated that the contractor will protect the existing utilities as required to keep them in service. | A line item has been included in the bid tab for shoring. It is anticipated that the contractor will protect the existing utilities as required to keep them in service during construction. |
| 5 | Will we be encroaching beyond curb and gutter into the parking lot of Variant Brewing Company? | No - work may include curb and gutter, but should not encroach into the parking lot area. |
| 6 | Line items 550-1480 and 550-1481 don't appear to have the correct depth measurements - can you check to determine if they are the correct measurement? | The length measure in LF are based on a depth "H" measured from top of pipe. |

All other terms, conditions, and deadlines remain the same.

COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the ITB to:

**City of Roswell – Purchasing Division
Roswell City Hall
38 Hill Street, Suite 130
Roswell, GA 30075**

I hereby acknowledge receipt of Addendum 2 and have incorporated the changes into my proposal response for the above mentioned ITB.

COMPANY NAME: _____ CONTACT PERSON: _____

ADDRESS: _____ CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____ EMAIL ADDRESS: _____

SIGNATURE: _____ DATE: _____